

POOL INSPECTION CHECK LIST



City of Albuquerque
Environmental Health Department
Consumer Health Protection Division
PO Box 1293
Albuquerque, NM 87103
311 or (505) 768-2638

Check Box $[\sqrt{\ }]$ when item completed. Once <u>ALL</u> items are marked completed Email this form to <u>OSanchez@cabq.gov</u> or <u>LStoller@cabq.gov</u> to request an opening inspection.

Annual Inspection is required to open
 Certified Pool Operator assigned to this facility is required

After pool is opened for swimming – Daily Records must be maintained.

PO	OL (ΩP	ERA	TOR
ГО	JL '	U .		11011

- □ Pool Operator's letter available for review
- Daily Operating & Accident Record readily available for review

POOL	STRU	JCTUF	₹E
-------------	------	--------------	----

- Ladders, Steps, Grab Rails secure and in good shape
- Diving Boards, Platforms, Blocks and Slides have non-skid surfaces and adequate area and depth of water
- ☐ Anti-entrapment grate on main drain securely attached
- ☐ Depth markings visible both on the pool wall and pool deck near edge
- Fill-Spout 6 inch (152 mm) air gap or approved backflow prevention device, spout does not constitute a safety hazard
 - □ Note: Pools filled using water hose must have an approved back flow device attached to the potable water spigot. This device is also required at spigot/attachment used to prime pumps.
- ☐ Handrails provided at all steps
- ☐ Skimmers, Gutters covered and working properly
- Barriers 48 inches (1.2 m) high and completely surrounding pool area
 - □ 1. Clear spaces between bars/railing 4 inches (102 mm) or less
 - □ 2. Bottom rail 4 inches (102 mm) or less above deck or grade
- ☐ Gates/Doors self-closing, self-latching
 - ☐ Hardware for permanent locking provided at 45 inches above ground
- □ No direct connection between city sewer and swimming pool

SAFETY EQUIPMENT

- Two or more U.S. Coast Guard approved ring-buoys a minimum of 18 inches (457 mm) outer diameter and attached throw line ¹/₄ inch thick (6 mm) approximately 0.50 (1/2) pool width plus 10 feet (3.1 m)
- □ Lifeline with floats at the break in grade
- \Box One pole with life hook 12 feet (3.7 m) or longer
- ☐ Safety signs conspicuously posted including:
 - □ 1. WARNING NO LIFEGUARD SERVICES PROVIDED. ALL CHILDREN UNDER THE AGE OF FOURTEEN (14) MUST BE ACCOMPANIED BY AN ADULT WITHIN THE BARRIER AREA. IN CASE OF EMERGENCY, CONTACT...
 - □ 2. NOTICE: WHILE THE POOL IS OPEN IF YOU HAVE ISSUES REGARDING POOL OPERATION, YOU CAN CONTACT SOMEONE BY......
 - □ 3. Emergency phone numbers
 - ☐ 4. Pool capacity/bather load 25 sq. ft. (2.3 m²)/person, Class A, B, C
 - □ 5. Resuscitation chart
- Lifeguard required for Class A pools or pools with greater than 1800 sq. ft. surface area * see note on new State Regulation
- ☐ First Aid Kit American Red Cross 24 unit or equivalent
- Pool chemicals stored properly
- Telephone on premises emergency Land Line (NO CELL PHONE) required that accurately identifies the pool location to the emergency responders answering the call
- ☐ If gas chlorine is used, contact our office for additional requirements
 - ☐ Ventilation .☐ Mask ☐ Alarm ☐ Ammonia ☐ Evacuation System☐ Lead Washers
- □ Equipment kept safe and fit

<u>OF</u>	PERATIONAL National Sanitation Foundation (NSF) approved disinfectant dispenser – mu Appropriate Test Kits – chlorine (DPD type), pH, and stabilizer (cyanuric ac		
	Pump, hair and lint strainer, pressure gauges, flow meters, skimmer strainer working properly		
	Flo Meter and Filter Pressure Gauges must be operational and accurate		
	SCELLANEOUS		
	No animals allowed within the barrier, except service animals. Grounds, buildings, dressing rooms, walk-ways, etc. clean and sanitary.		
	Daily operating records are to be maintained. All accidents are to be record-	ed and readily available for inspection	
	The contact person (18 years or older) should be available at all times the po		
	telephone, pager or cell phone and be able to respond within 30 minutes.	<u></u>	
	No curbs or other tripping hazards.		
	No glass or rigid plastic.		
W	ATER QUALITY		
	Stabilizer (cyanuric acid) concentration less than 100 ppm		
	pH of pool water maintained between 7.2 and 8.0		
	Clarity – main drain clearly visible from the runway around the deep area.		
	Chlorination:	id Octobration	
	 1. Non-stabilized chlorine maintained between 1 and 5 ppm * Complie 2. Stabilized chlorine residual maintained between 1.0 and 4.0 ppm 	s with new State Regulation	
	Bromination – bromine maintained between 2.0 and 6.0 ppm		
	Wading and Whirlpools shall be disinfected to maintain a disinfectant residu	ual 50% higher; i.e., 1.5 ppm instead of 1.0 ppm	
	chlorine on stabilized pools		
	Total dissolved solids shall be lower than 3000 ppm or 2000 ppm over natur		
	Daily water quality logs must be maintained using the Department approved	Form. * Can be downloaded from cabq.gov web	
	site.		
SP	'AS		
	Precaution sign		
	Chlorination maintained between 2 and 5 ppm *Complies with new State Re	egulation	
	Temperature 104°F (40°C) max		
_	□ Shatterproof thermometer		
	Jets on 15-minute timer or clock visible to swimmers	were learned and and the dealer	
	Spas with built-in seating shall indicate depth of seating level, as well as the maximum depth, on the deck Pool capacity – 10 sq. ft. (0.9 m ²)/person		
_	1 ool capacity – 10 sq. it. (0.9 iii)/pcrson		
CE	RTIFICATION		
	Swimming pool operators must successfully complete a training course	approved by the enforcement authority	
	Certified Operator Name:	CPO #	
	Responsible for Pool/Spa: (name)	Phone Contact #	
	Pool/Spa Address Street:	Zip Code:	

Important Notes:

1. ANY renovations or modifications (including equipment) will require meeting all new State of New Mexico Regulations.

Facility Contact Owner/Manager Name: Phone Contact#_____

- 2. ANY renovations or modifications (including equipment) will require all work to be performed by a licensed commercial contractor from an approved set of plans.
- 3. New State Lifeguard Requirements: For pools with a surface area greater than 2500 sq. ft. or a depth greater than five (5) feet require lifeguards *unless the occupancy bather load is calculated at 1 person per 50 sq. ft. surface area.*
- 4. Salt Chlorine Generators will only be approved if they are rated for commercial applications and can maintain required residual chlorine levels.

2009 Request for Opening Inspection

This request for a pre-opening inspection should be completed by the Certified Pool Operator in charge of this Facility

To request a pre-opening operational inspection this entire 3 page form must be completed and Emailed to Consumer Health Protection to either of the following persons;

OSanchez@cabq.gov or LStoller@cabq.gov

Certified Pool Operator Name:	CPO #				
CPO Mailing Address:		Cell Phone #			
I am responsible for the following facility(s):					
Facility Name:	Address;				
Owner/Manager Name:		Contact Phone #:			
Cell Phone #	Fax #:				
Pool/ Spa #1 Name	Bather Load:	Volume in Gallons			
Surface Area: Calculated at 1 person per 25 sq ft or at 50 sq ft.	Depth:	Lifeguard: Yes / I	٧o		
Type of Disinfection: Bromine, Chlorine or Other					
Pool/ Spa #2 Name	Bather Load:	Volume in Gallons			
Surface Area: Calculated at 1 person per 25 sq ft or at 50 sq ft.	Depth:	Lifeguard: Yes / I	No		
Type of Disinfection: Bromine, Chlorine or Other					
Pool/ Spa #3 Name	Bather Load:	Volume in Gallons			
Surface Area: Calculated at 1 person per 25 sq ft or at 50 sq ft.	Depth:	Lifeguard: Yes / I	٧o		
	Name of CHPD Inspector:				
Please indicate the times you are available for inspection:	Hours from	То			
List the Dates you are available for inspection: Dates Pro	eferred:				

From past years previous experience you are all aware of how extremely busy all of the Consumer Health Protection Pool Inspectors are this time of year. We will make every effort to complete your pre-opening inspection on time and on the date you request. Upon receipt of this Request for Inspection Form, your inspector will be notified that you are ready and WILL CALL YOU TO SCHEDULE AND CONFIRM THE EXACT TIME AND DATE OF THE INSPECTION. Make absolutely certain that everything is working properly and in order to assure your facility will pass inspection. All failed inspections will only be re-inspected AFTER ALL OTHER SCHEDULED INSPECTIONS HAVE BEEN COMPLETED. A second follow-up inspection is very difficult with almost 500 pools needing inspection and wanting to open by Memorial Day. Check with your inspector PRIOR to your scheduled inspection if you have any questions or need help with any problem.